

CERTIFICATE NO : 11118-TC-00247

CERTIFICATE DATE : 22-5-2019

CUSTOMER DETAILS

SITE DETAILS

CLIENT : HINDUSTAN PETROLEUM CORP. LTD
REGIONAL OFFICE : HISAR
SALES AREA : JIND
ADDRESS : HISAR RETAIL RO, 2ND FLOOR , SJ TOWERS,
: SECTOR - 13, TOSHAM ROAD, HISAR
: HARYANA - 125005, CONTACT NO.- 9711040463
PROJ/COMPLAINT : 1920050299

SITE NAME : KALLI RAM MITTAL AND BROTHERS
LOCATION/DISTRICT : H P C DEALER NARWANA DISTT JIND
126116 , JIND
CUSTOMER CODE : 11816210
CONTACT PERSON : AMIT MITTAL
EMAIL ID : AMIT02340@GMAIL.COM

EARTH PIT ELECTRODE RESISTANCE TEST CERTIFICATE

EARTH PIT NO .	EARTH PIT TYPE (PLATE/PIPE)	RESISTANCE OF EARTH PIT (OHM)	EARTH PIT IDENTIFICATION BOARD AVAILABLE (YES/NO)	FUNNEL AVAILABLE (YES/NO)	CLAMP AVAILABLE (YES/NO)	SIZE OF PIPES (50MM) YES/NO	CLAMP NUTBOLT REPLACED YES/NO	CHAMBER SIZE (18" x 18") YES/NO	CHAMBER COVER AVAILABLE YES/NO
1	PIPE	1.34	YES	YES	YES	YES	YES	YES	YES
2	PIPE	0.30	YES	YES	YES	YES	YES	YES	YES
3	PIPE	0.88	YES	YES	YES	YES	YES	YES	YES

TESTING DATE : 22-5-2019

NEXT DUE DATE : 8-11-2020

NOTE :-

- KINDLY MAINTAIN THE ALL EARTH PITS IN WET CONDITION FOR BETTER SAFETY.
- EARTHPIT CHAMBER SHOULD BE KEPT CLEAN.
- EARTHING TESTING JOB CERTIFICATE IS VALID ONLY FOR SIX MONTHS FROM THE DATE OF TESTING.
- AS PER OISD-137, THE EARTH RESISTANCE VALUE OF AN EARTHING SYSTEM TO GENEREL MASS OF THE EARTH SHOULD NOT EXCEED.
 - 4 OHMS FOR ELECTRICAL SYSTEMS AND METALLIC STRUCTURES .
 - 7 OHMS FOR STORAGE TANKS.
 - 1 OHMS FOR MAIN EARTH GRID, AND BONDING CONNECTIONS BETWEEN JOINTS IN PIPELINES AND ASSOCIATED FACILITIES.
 - 2 OHMS FOR EACH ELECTRODE TO THE GENERAL MASS OF THE EARTH.
- * 'NA' MEANS NOT AVAILABLE.



SCAN HERE
TO GET CERTIFICATE.

CERTIFICATE NO : 11118-TC-00247

CUSTOMER DETAILS

CLIENT : HINDUSTAN PETROLEUM CORP. LTD
 REGIONAL OFFICE : HISAR
 SALES AREA : JIND
 ADDRESS : HISAR RETAIL RO, 2ND FLOOR , S.J TOWERS,
 : SECTOR - 13, TOSHAM ROAD, HISAR
 : HARYANA - 125005, CONTACT NO.- 9711040463
 PROJ/COMPLAINT : 1920050299

CERTIFICATE DATE : 22-5-2019

SITE DETAILS

SITE NAME : KALLI RAM MITTAL AND BROTHERS
 LOCATION/DISTRICT : H P C DEALER NARWANA DISTT JIND
 : 126116 , JIND
 CUSTOMER CODE : 11816210
 CONTACT PERSON : AMIT MITTAL
 EMAIL ID : AMIT02340@GMAIL.COM

DU HOSE PIPE CONTINUITY TEST REPORT

SR NO.	DU MAKE MODEL SERIAL NO.	NOZEL-1 PRODUCT CONT.	NOZEL-2 PRODUCT CONT.	NOZEL-3 PRODUCT CONT.	NOZEL-4 PRODUCT CONT.	NOZEL-5 PRODUCT CONT.	NOZEL-6 PRODUCT CONT.	NOZEL-7 PRODUCT CONT.	NOZEL-8 PRODUCT CONT.
1	MIDCO SFJ1112ASPI 13FH1641V	PETROL OK	NA	NA	NA	NA	NA	NA	NA
2	MIDCO SFK2224ASSPI 14JH0610V	PETROL OK	DIESEL OK	NA	NA	NA	NA	NA	NA
3	MIDCO SFH2224AHPI 11BH0053V	DIESEL OK	DIESEL OK	NA	NA	NA	NA	NA	NA
4	MIDCO SFJ1112AHPI 13CH1375V	DIESEL OK	NA	NA	NA	NA	NA	NA	NA

TESTING DATE : 22-5-2019

NOTE :-

1 . * 'NA' MEANS NOT AVAILABLE.



SCAN HERE
TO GET CERTIFICATE

CERTIFICATE NO : 11118-TC-00247**CUSTOMER DETAILS**

CLIENT : HINDUSTAN PETROLEUM CORP. LTD
REGIONAL OFFICE : HISAR
SALES AREA : JIND
ADDRESS : HISAR RETAIL RO, 2ND FLOOR , S,J TOWERS,
: SECTOR - 13, TOSHAM ROAD, HISAR
: HARYANA - 125005, CONTACT NO.- 9711040463
PROJ/COMPLAINT : 1920050299

CERTIFICATE DATE : 22-5-2019**SITE DETAILS**

SITE NAME : KALLI RAM MITTAL AND BROTHERS
LOCATION/DISTRICT : H P C DEALER NARWANA DISTT JIND
126116 , JIND
CUSTOMER CODE : 11816210
CONTACT PERSON : AMIT MITTAL
EMAIL ID : AMIT02340@GMAIL.COM

DECANTATION RUBBER HOSE PIPE CONTINUITY TEST REPORT

THIS IS TO CERTIFIED THAT WE HAVE CHECKED THE DECANTING RUBBER HOSE PIPE AT **KALLI RAM MITTAL AND BROTHERS**. WE CONFIRM THAT THE RUBBER HOSE PIPE IS **AVAILABLE** AT SITE. THE CONDITION OF THE HOSE PIPE ARE GIVEN BELOW :

1. CONTINUITY OF THE RUBBER HOSE PIPE FROM ONE END TO OTHER END	OK
2. BRASS COUPLINGS AT BOTH END ARE	AVAILABLE
3. PHYSICAL CONDITION OF THE PIPE IS	GOOD

**TESTING DATE :** 22-5-2019**NOTE :-**

1 . * 'NA' MEANS NOT AVAILABLE.



SCAN HERE
TO GET CERTIFICATE

CERTIFICATE NO : 11118-TC-00247

CUSTOMER DETAILS

CLIENT : HINDUSTAN PETROLEUM CORP. LTD
REGIONAL OFFICE : HISAR
SALES AREA : JIND
ADDRESS : HISAR RETAIL RO, 2ND FLOOR , S,J TOWERS,
: SECTOR - 13, TOSHAM ROAD, HISAR
: HARYANA - 125005, CONTACT NO.- 9711040463
PROJ/COMPLAINT : 1920050299

CERTIFICATE DATE : 22-5-2019

SITE DETAILS

SITE NAME : KALLI RAM MITTAL AND BROTHERS
LOCATION/DISTRICT : H P C DEALER NARWANA DISTT JIND
126116 , JIND
CUSTOMER CODE : 11816210
CONTACT PERSON : AMIT MITTAL
EMAIL ID : AMIT02340@GMAIL.COM

EARTH/CROCODILE CLAMP CONTINUITY TEST REPORT

THIS IS TO CERTIFIED THAT WE HAVE CHECKED THE CROCODILE CLAMP AT **KALLI RAM MITTAL AND BROTHERS** . WE CONFIRM THAT THE CROCODILE CLAMP IS **NOT AVAILABLE** AT SITE. THE CONDITION OF THE CROCODILE CLAMP ARE GIVEN BELOW :

TESTING DATE : 22-5-2019

NOTE :-

1 . * 'NA' MEANS NOT AVAILABLE.



SCAN HERE
TO GET CERTIFICATE



ELECTRICALS PVT. LTD.

ADDRESS: 2nd Floor, Plot no - 133, Near
Syndicate Bank, Tilpat, Faridabad -121003,
Haryana.

PH NO.: 0129-2279955

'A' CLASS LICENCE NO : H-2501/2016

CERTIFICATE NO : 11118-TC-00247

CUSTOMER DETAILS

CLIENT : HINDUSTAN PETROLEUM CORP. LTD
REGIONAL OFFICE : HISAR
SALES AREA : JIND
ADDRESS : HISAR RETAIL RO, 2ND FLOOR , S,J TOWERS,
: SECTOR - 13, TOSHAM ROAD, HISAR
: HARYANA - 125005, CONTACT NO.- 9711040463
PROJ/COMPLAINT : 1920050299

CERTIFICATE DATE : 22-5-2019

SITE DETAILS

SITE NAME : KALLI RAM MITTAL AND BROTHERS
LOCATION/DISTRICT : H P C DEALER NARWANA DISTT JIND
126116 , JIND
CUSTOMER CODE : 11816210
CONTACT PERSON : AMIT MITTAL
EMAIL ID : AMIT02340@GMAIL.COM

DECANTATION EARTH POINT CONTINUITY TEST REPORT

THIS IS TO CERTIFIED THAT WE HAVE CHECKED THE CROCODILE CLAMP AT **KALLI RAM MITTAL AND BROTHERS** . WE CONFIRM THAT THE CROCODILE CLAMP IS **NOT AVAILABLE** AT SITE. THE CONDITION OF THE CROCODILE CLAMP ARE GIVEN BELOW :



TESTING DATE : 22-5-2019

NOTE :-

1 . * 'NA' MEANS NOT AVAILABLE.



SCAN HERE
TO GET CERTIFICATE